

KIK - B-9833D

Prepared to OSHA, ACC, ANSI, NOHSC, WHMIS, 2001/58 & 1272/2008/EC Standards SDS Revision: 1.0 SDS Revision Date: 11-16-2016

1. PRODUCT & COMPANY IDENTIFICATION						
1.1	Product Name:	Kenra Heat Block Hairspray				
1.2	Chemical Name:	Aerosol Hair Spray				
1.3	Synonyms:	Kenra – Heat Block Hairspray 55%VOC – B-9833 D				
1.4	Trade Names:	Heat Block Hairspray				
1.5	Product Uses/ Restrictions	Professional and Cosmetic Use				
1.6	Distributor's Name:	KIK Custom Products				
1.7	Distributor's Address:	2740 Middlebury Street, Elkhart, Indiana 46515				
1.8	Emergency Phone:	Poison Control Center (Medical): (866) 366-5048; CHEMTREC: +1 (800) 424-9300 /+1 (703)527-3887				
1.9	Business Phone / Fax:	+1 (574) 295-0000 / +1 (574) 295-1709				

#### 2. HAZARDS IDENTIFICATION

Hazard Identification: This product is classified as a HAZARDOUS SUBSTANCE and as DANGEROUS GOODS according to the 2.1 classification criteria of NOHSC: 1088 (2004) and ADG Code (Australia) WARNING! FLAMMABLE AEROSOL. PRESSURIZED CONTAINER: MAY BURST IF HEATED. HIGHLY FLAMMABLE LIQUID AND VAPOR. CAUSES EYE IRRITATION. Classification: Level 1 Aerosol; Category 2 Flammable Aerosol Hazard Statements (H): H-223- Flammable Aerosol. H229-Pressurized container: may burst if heated. H320 – Causes eye irritation. Precautionary Statement (P): P210 – Keep away from heat, hot surfaces, sparks, open flames and other ignition sources. No Smoking. P211 – Do not spray on an open flame or other ignition source. P251 – Do not pierce or burn, even after use. P261 – avoid breathing vapors/spray. P271 – Use only in well-ventilated area. P304+P340 – IF INHALED; Remove person to fresh air and keep comfortable for breathing. P305+P351+338 – IF INEYES; Rinse cautiously with water for several minutes. Remove contact lenses, if present, continue rinsing. P337+P313 – If eye irritation persists: Get medical advice/attention. P410+P412 - Protect from sunlight. Do no expose to temperature exceeding 48°C (120 °F).



### 3. COMPOSITION & INGREDIENT INFORMATION

P501 – Dispose of contents/container to licensed and permitted disposal or recycling facility.

Substance / Chemical Name(s)	CAS No.	EINECS No.	%	Other
DIFLUOROETHANE (R-152a)	75-37-6	200-866-1	20-40	Flam. Gas 1; H220
Ethanol (SD Alcohol 40B)	64-17-5	200-578-6	30 - 50	Flam. Liq. 2; H225

#### 4. FIRST AID MEASURES

4.1	First Aid:	Ingestion:	If ingested, do not induce vomiting! If product has been swallowed, drink plenty of water or milk IMMEDIATELY. If the patient is vomiting, continue to offer water or milk. Never give water or milk to an unconscious person. Contact the nearest Poison Control Center or local emergency number. Provide an estimate of the time at which the material was ingested and the amount of the substance that was swallowed.
		Skin:	If irritation occurs & product is on the skin, rinse thoroughly with lukewarm water, followed by a thorough washing of the affected area with plenty of soap and water. Remove contaminated clothing and wash thoroughly before ruse. If irritation, redness or swelling persists, consult a physician immediately.
		Eyes:	If product get in the eyes, flush with copious amounts of lukewarm water for at least 15 minutes. Raise and lower eyelid(s) while flushing to ensure thorough irrigation. If problems persist seek immediate medical attention.
		Inhalation:	Remove victim to fresh air and keep comfortable for breathing.
4.2	Effects of Exposure:	Ingestion:	If product is swallowed, may cause nausea, vomiting and/or diarrhea and central nervous system depression.
		Skin:	May be irritating to skin. The product can cause allergic skin reactions (e.g., rashes, welts, dermatitis) in some sensitive individuals upon prolonged or repeated exposure.
		Eyes:	Moderately irritating to the eyes.
		Inhalation:	Vapors of this product may be moderately irritating to the nose, throat and other tissues of the respiratory system. Symptoms of overexposure can include coughing, wheezing, nasal congestion, and



KIK - B-9833D

			IIS, 2001/58 & 1272/2008/EC Standards SDS Redifficulty breathing. Inhalation of concentrated vapors	c can cauco noru	ious system doni	roccion la a			
				s can cause nerv	vous system depi	ression (e.g.,			
_	6		drowsiness, dizziness, headaches, nausea).						
.3	Symptoms of Overexposure	Ingestion:	May cause nausea, vomiting and/or diarrhea and cent						
		Prolonged contact with skin may result in bleaching and irritation of skin. The product can cause allergic skin reactions (e.g., rashes, welts, dermatitis) in some sensitive individuals. Symptoms of skin							
		Skin:	s of skin						
			overexposure may include redness, itching, and irritati						
		Evoc	Overexposure in eyes, may cause redness, itching and watering (risk of serious damage to eyes) Contact						
		Lyes.	may cause mild eye irritation including stinging, watering and redness.						
		Inhalation: Symptoms of overexposure can include coughing, wheezing, nasal congestion, and difficulty breathing.							
		Moderate irri	ation to eyes and skin near affected areas. Additional	y, high concentr	rations of vapors	can cause			
.4	Acute Health Effects:	drowsiness, d	zziness, headaches and nausea.		·				
		No harmful oi	chronic health effects are expected to occur from a sir	ngle accidental i	ngestion. These	ingredients may			
			in and mucous membrane of the eye and respiratory s						
1.5	Chronic Health Effects:		come sensitive individuals. May also induce skin sensiti						
		allergic derma	· · · · · · · · · · · · · · · · · · ·		,,pe				
.6	Target Organs:		piratory system.						
.0 .7	Medical Conditions		nazards may be delayed. Most common symptoms	HEALTH		1			
. /						3			
	Aggravated by Exposure		ng properties to eyes, respiratory system and skin.	FLAMMABILIT					
		_	atological conditions (such as eczema) and respiratory	PHYSICAL HAZ		0			
			ch as bronchial asthma and/or bronchitis) may be	PROTECTIVE E		В			
		exacerbated.		EYES	SK				
					IN				
			5. FIREFIGHTING MEASURES						
_	I	T							
.1	Fire and Explosion Hazards:	Level 1 Aerosol (NFPA 30B). Aerosols may burst at temperatures above 120° F (48°C). Cool							
		uninvolved containers to prevent possible bursting. Aerosols may be projectile hazards when							
			· · · · · · · · · · · · · · · · · · ·	•					
		uninvolved co	ntainers to prevent possible bursting. Aerosols may be	projectile haza	rds when				
		uninvolved co bursting. If a	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is complete	e projectile haza e. Containers m	rds when nay rupture				
		uninvolved co bursting. If a and release fla	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is complete ammable liquids and/or exposed gases if exposed to the	e projectile haza e. Containers m e heat of fire. K	rds when nay rupture				
		uninvolved co bursting. If a and release fla containers co	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is complete ammable liquids and/or exposed gases if exposed to the of by spraying them with water until the fire has been e	e projectile haza e. Containers m e heat of fire. K	rds when nay rupture	3			
	Extinguishing Methods:	uninvolved co bursting. If ae and release fla containers co Water Fog, Fo	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is complete ammable liquids and/or exposed gases if exposed to the ol by spraying them with water until the fire has been e am, CO <sub>2</sub> , Dry Chemical	e projectile haza e. Containers m e heat of fire. K extinguished.	rds when nay rupture Keep	3			
	Extinguishing Methods: Firefighting Procedures:	uninvolved co bursting. If ac and release fla containers co Water Fog, Fo As in any fire,	ntainers to prevent possible bursting. Aerosols may be erosols are bursting, stay clear until bursting is complete ammable liquids and/or exposed gases if exposed to the oll by spraying them with water until the fire has been e am, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing	e projectile haza e. Containers m e heat of fire. K extinguished. apparatus (pres	rds when nay rupture (eep	130			
5.2 5.3		uninvolved co bursting. If ac and release fla containers co Water Fog, Fo As in any fire,	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is complete ammable liquids and/or exposed gases if exposed to the ol by spraying them with water until the fire has been e am, CO <sub>2</sub> , Dry Chemical	e projectile haza e. Containers m e heat of fire. K extinguished. apparatus (pres	rds when nay rupture (eep	130			
		uninvolved co bursting. If ac and release flac containers co Water Fog, Fo As in any fire, demand_ and	ntainers to prevent possible bursting. Aerosols may be erosols are bursting, stay clear until bursting is complete ammable liquids and/or exposed gases if exposed to the oll by spraying them with water until the fire has been e am, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing	e projectile haza e. Containers m e heat of fire. K extinguished. apparatus (pres ter the fire is ou	rds when nay rupture (eep ssure- it. Use	1 30			
		uninvolved co bursting. If ac and release flac containers co Water Fog, Fo As in any fire, demand_ and water spray to	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is complete ammable liquids and/or exposed gases if exposed to the old by spraying them with water until the fire has been eam, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well afto cool fire-exposed surfaces and to protect personnel.	e projectile haza e. Containers m e heat of fire. K extinguished. apparatus (pres ter the fire is our Fight fire upwin	rds when nay rupture Geep ssure- t. Use d. Prevent	1 30			
		uninvolved co bursting. If ac and release flac containers co Water Fog, Fo As in any fire, demand_ and water spray to runoff from fi	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is complete ammable liquids and/or exposed gases if exposed to the old by spraying them with water until the fire has been eam, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well afto cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring the control or dilution from entering sewers, drains, dring the control or dilution from entering sewers, drains, dring the control or dilution from entering sewers, drains, dring the control or dilution from entering sewers, drains, dring the control or dilution from entering sewers.	e projectile haza e. Containers me e heat of fire. K extinguished. apparatus (pres ter the fire is ou Fight fire upwind king water supp	rds when nay rupture Geep ssure- it. Use d. Prevent bly, or any	1 0			
		uninvolved co bursting. If ac and release flac containers co Water Fog, Fo As in any fire, demand_ and water spray to runoff from fi natural water	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is complete ammable liquids and/or exposed gases if exposed to the blood by spraying them with water until the fire has been eam, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well afto cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including N	e projectile haza e. Containers m e heat of fire. K extinguished. apparatus (pres ter the fire is ou Fight fire upwin- king water supp IOSH-approved	rds when nay rupture deep ssure- it. Use d. Prevent ply, or any positive	1 0			
		uninvolved co bursting. If ac and release fla containers co. Water Fog, Fo As in any fire, demand_ and water spray to runoff from fi natural water pressure self-	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is complete ammable liquids and/or exposed gases if exposed to the blood by spraying them with water until the fire has been eam, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well afforced for cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including National contained breathing apparatus to protect against poters.	e projectile haza e. Containers m e heat of fire. K extinguished. apparatus (pres ter the fire is ou Fight fire upwin- king water supp IOSH-approved	rds when nay rupture deep ssure- it. Use d. Prevent ply, or any positive	1 0			
		uninvolved co bursting. If ac and release fla containers co. Water Fog, Fo As in any fire, demand_ and water spray to runoff from fi natural water pressure self-	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is complete ammable liquids and/or exposed gases if exposed to the blood by spraying them with water until the fire has been eam, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well afto cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including N	e projectile haza e. Containers m e heat of fire. K extinguished. apparatus (pres ter the fire is ou Fight fire upwin- king water supp IOSH-approved	rds when nay rupture deep ssure- it. Use d. Prevent ply, or any positive	1 0			
		uninvolved co bursting. If ac and release flac containers co Water Fog, Fo As in any fire, demand_ and water spray to runoff from fi natural water pressure self- or decomposi	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is complete ammable liquids and/or exposed gases if exposed to the old by spraying them with water until the fire has been eam, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well afto cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including Not contained breathing apparatus to protect against poter tion products and oxygen deficiencies.	e projectile haza e. Containers me e heat of fire. K extinguished. apparatus (pres ter the fire is ou Fight fire upwind king water supp IOSH-approved ntial hazardous o	rds when nay rupture deep ssure- it. Use d. Prevent ply, or any positive	1 30			
		uninvolved co bursting. If ac and release flac containers co Water Fog, Fo As in any fire, demand_ and water spray to runoff from fi natural water pressure self- or decomposi	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is complete ammable liquids and/or exposed gases if exposed to the blood by spraying them with water until the fire has been eam, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well afforced for cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including National contained breathing apparatus to protect against poters.	e projectile haza e. Containers me e heat of fire. K extinguished. apparatus (pres ter the fire is ou Fight fire upwind king water supp IOSH-approved ntial hazardous o	rds when nay rupture deep ssure- it. Use d. Prevent ply, or any positive	1 0			
5.3	Firefighting Procedures:	uninvolved co bursting. If ac and release flac containers co. Water Fog, Fo As in any fire, demand_ and water spray to runoff from fi natural water pressure self- or decomposi	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is complete ammable liquids and/or exposed gases if exposed to the old by spraying them with water until the fire has been eam, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well afto cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including Not contained breathing apparatus to protect against poter tion products and oxygen deficiencies.  6. ACCIDENTIAL RELEASE MEASUR	e projectile haza e. Containers me e heat of fire. K extinguished. apparatus (pres ter the fire is ou Fight fire upwin- king water supp IOSH-approved ntial hazardous of	ssure- it. Use d. Prevent bly, or any positive combustion	1 0			
		uninvolved co bursting. If ac and release fla containers co. Water Fog, Fo As in any fire, demand_ and water spray to runoff from fi natural water pressure self- or decomposi	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is complete ammable liquids and/or exposed gases if exposed to the blood by spraying them with water until the fire has been eam, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well afto cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including Not contained breathing apparatus to protect against poter tion products and oxygen deficiencies.  6. ACCIDENTIAL RELEASE MEASUR agany spill or leak, individuals involved in spill cleanup of the surface of the su	e projectile haza e. Containers me e heat of fire. K extinguished. apparatus (pres ter the fire is ou Fight fire upwin- king water supp IOSH-approved ntial hazardous of	ssure- it. Use d. Prevent bly, or any positive combustion	1 0 Protective			
5.3	Firefighting Procedures:	uninvolved co bursting. If ac and release fla containers co. Water Fog, Fo As in any fire, demand_ and water spray to runoff from fi natural water pressure self- or decomposi	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is complete ammable liquids and/or exposed gases if exposed to the lot by spraying them with water until the fire has been eam, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well afto cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including Not contained breathing apparatus to protect against poter tion products and oxygen deficiencies.  6. ACCIDENTIAL RELEASE MEASUR agany spill or leak, individuals involved in spill cleanup of the process.	e projectile haza e. Containers m e heat of fire. K extinguished.  apparatus (prester the fire is our Fight fire upwinking water supplicities water supplies water supplicities water supplies water supplies water supplies water supplies water	ssure- it. Use d. Prevent poly, or any positive combustion				
5.3	Firefighting Procedures:	uninvolved co bursting. If ac and release fla containers co. Water Fog, Fo As in any fire, demand_ and water spray to runoff from fi natural water pressure self- or decomposi	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is complete ammable liquids and/or exposed gases if exposed to the lot by spraying them with water until the fire has been eam, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well afto cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including Not contained breathing apparatus to protect against poter tion products and oxygen deficiencies.  6. ACCIDENTIAL RELEASE MEASUR and spill or leak, individuals involved in spill cleanup (PE).	e projectile haza e. Containers m e heat of fire. K extinguished.  apparatus (prester the fire is ou- Fight fire upwin- king water supploSH-approved ntial hazardous of	rotective eyewea	ar. Use a non-			
5.3	Firefighting Procedures:	uninvolved co bursting. If ac and release fla containers co. Water Fog, Fo As in any fire, demand_ and water spray to runoff from fi natural water pressure self- or decomposi Before cleanin Equipment (P Small spills W combustible r	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is complete ammable liquids and/or exposed gases if exposed to the lot by spraying them with water until the fire has been eam, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well afto cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including Not contained breathing apparatus to protect against poter tion products and oxygen deficiencies.  6. ACCIDENTIAL RELEASE MEASUR and spill or leak, individuals involved in spill cleanup of the protection appropriate personal protective equipment including that enterial such as vermiculite or sand to soak up the protection and the protection are such as vermiculite or sand to soak up the protection are such as the protective equipment including that enterial such as vermiculite or sand to soak up the protective equipment including the	e projectile haza e. Containers m e heat of fire. K extinguished.  apparatus (prester the fire is ou- Fight fire upwin- king water supploSH-approved atial hazardous of  EES  must wear approved and place in	rotective eyeweanto a container for	ar. Use a non- or later disposal.			
5.3	Firefighting Procedures:	uninvolved co bursting. If ac and release fla containers co. Water Fog, Fo As in any fire, demand_ and water spray to runoff from fi natural water pressure self- or decomposi Before cleanin Equipment (P Small spills W combustible r not use water	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is complete ammable liquids and/or exposed gases if exposed to the blood by spraying them with water until the fire has been eam, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well afto cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including Not contained breathing apparatus to protect against poter tion products and oxygen deficiencies.  6. ACCIDENTIAL RELEASE MEASUR and spill or leak, individuals involved in spill cleanup of the protection and the proposition of the protection and the protection and the protection and the protection among the protection and the protection	e projectile haza e. Containers m e heat of fire. K extinguished.  apparatus (prester the fire is our Fight fire upwinding water supplication of the contained	rotective eyeweanto a container foterial using non-s	ar. Use a non- or later disposal. sparking material			
5.3	Firefighting Procedures:	uninvolved co bursting. If ac and release fla containers co. Water Fog, Fo As in any fire, demand_ and water spray to runoff from fi natural water pressure self- or decomposi Before cleanin Equipment (P Small spills W combustible r not use water (e.g., plastic b	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is complete ammable liquids and/or exposed gases if exposed to the blook spraying them with water until the fire has been eam, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well afto cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including Not contained breathing apparatus to protect against poter tion products and oxygen deficiencies.  6. ACCIDENTIAL RELEASE MEASUR and spill or leak, individuals involved in spill cleanup of the protection appropriate personal protective equipment including that are appropriate personal protective equipment including that are appropriate as a serious contained to soak up the protection and to soak up material rooms, shovels, dustpans) and place into a plastic contained to so the serious contained to soak up material rooms, shovels, dustpans) and place into a plastic contained to soak up the protection products and such as "speedy dry" to soak up material rooms, shovels, dustpans) and place into a plastic contained to the serious containe	e projectile haza e. Containers m e heat of fire. K extinguished.  apparatus (prester the fire is our Fight fire upwinding water supplication of the containers of the containers of the containers of the container or plastic less.	rotective eyeweanto a container foterial using non-siliner within anoth	ar. Use a non- or later disposal. sparking material her container.			
5.3	Firefighting Procedures:	uninvolved co bursting. If ac and release fla containers co. Water Fog, Fo As in any fire, demand_ and water spray to runoff from fi natural water pressure self- or decomposi Before cleanin Equipment (P Small spills W combustible r not use water (e.g., plastic b	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is complete ammable liquids and/or exposed gases if exposed to the blood by spraying them with water until the fire has been eam, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well afto cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including Not contained breathing apparatus to protect against poter tion products and oxygen deficiencies.  6. ACCIDENTIAL RELEASE MEASUR and spill or leak, individuals involved in spill cleanup of the protection and the proposition of the protection and the protection and the protection and the protection among the protection and the protection	e projectile haza e. Containers m e heat of fire. K extinguished.  apparatus (prester the fire is our Fight fire upwinding water supplication of the contained	rotective eyeweanto a container foterial using non-siliner within anoth	ar. Use a non- or later disposal. sparking material her container.			
.3	Firefighting Procedures:	uninvolved co bursting. If ac and release fli- containers co. Water Fog, Fo As in any fire, demand_ and water spray to runoff from fi natural water pressure self- or decomposi Before cleanin Equipment (P Small spills W combustible r not use water (e.g., plastic b Large spills: Ke	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is complete ammable liquids and/or exposed gases if exposed to the old by spraying them with water until the fire has been eam, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well afto cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including National products and oxygen deficiencies.  6. ACCIDENTIAL RELEASE MEASUR against potention products and oxygen deficiencies.  6. ACCIDENTIAL RELEASE MEASUR against potention products and oxygen deficiencies.  6. ACCIDENTIAL RELEASE MEASUR against potention products and oxygen deficiencies.	e projectile haza e. Containers m e heat of fire. K extinguished.  apparatus (prester the fire is our Fight fire upwind king water supploSH-approved atial hazardous of  EES  must wear approved fuct and place ir . Sweep up matainer or plastic I way from spill.	rotective eyeweanto a container foterial using non-stay upwind and	ar. Use a non- or later disposal. sparking material her container. I away from spill o			
.3	Firefighting Procedures:	uninvolved co bursting. If ac and release flac containers co. Water Fog, Fo As in any fire, demand_ and water spray to runoff from fi natural water pressure self- or decomposi Before cleanin Equipment (P Small spills W combustible r not use water (e.g., plastic b Large spills: K release. Isola	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is completed ammable liquids and/or exposed gases if exposed to the policy spraying them with water until the fire has been exam, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well after cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including Not contained breathing apparatus to protect against poter tion products and oxygen deficiencies.  6. ACCIDENTIAL RELEASE MEASUR and any spill or leak, individuals involved in spill cleanup of the products are appropriate personal protective equipment including naterial such as vermiculite or sand to soak up the product or a material such as "speedy dry" to soak up material rooms, shovels, dustpans) and place into a plastic contained incompatible materials (e.g., organics such as oil) at the immediate hazard area and keep unauthorized personal protective equipment including the immediate hazard area and keep unauthorized personal terminaterials (e.g., organics such as oil) at the immediate hazard area and keep unauthorized personal protective equipment including the immediate hazard area and keep unauthorized personal terminaterials (e.g., organics such as oil) at the immediate hazard area and keep unauthorized personal protective equipment including the immediate hazard area and keep unauthorized personal protective equipment including the immediate hazard area and keep unauthorized personal protective equipment including the immediate hazard area and keep unauthorized personal protective equipment including the immediate hazard area and keep unauthorized personal protective equipment including the immediate hazard area and keep unauthorized personal protective equipment including the immediate hazard area and keep unauthorized personal protective equipment including the immediate hazard ar	e projectile haza e. Containers me e heat of fire. K extinguished.  apparatus (prester the fire is our Fight fire upwind king water supploSH-approved atial hazardous of  EES  must wear approved fluct and place ir . Sweep up mat ainer or plastic I way from spill. connel out of area	rotective eyeweanto a container foterial using non-sliner within anotl Stay upwind and a. Stop spill or rote.	ar. Use a non- or later disposal. sparking material her container. I away from spill delease if it can be			
.3	Firefighting Procedures:	uninvolved co bursting. If ac and release flac containers co. Water Fog, Fo As in any fire, demand_ and water spray to runoff from fi natural water pressure self- or decomposi Before cleanin Equipment (P Small spills W combustible r not use water (e.g., plastic b Large spills: K release. Isola	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is complete ammable liquids and/or exposed gases if exposed to the old by spraying them with water until the fire has been eam, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well afto cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including National products and oxygen deficiencies.  6. ACCIDENTIAL RELEASE MEASUR against potention products and oxygen deficiencies.  6. ACCIDENTIAL RELEASE MEASUR against potention products and oxygen deficiencies.  6. ACCIDENTIAL RELEASE MEASUR against potention products and oxygen deficiencies.	e projectile haza e. Containers me e heat of fire. K extinguished.  apparatus (prester the fire is our Fight fire upwind king water supploSH-approved atial hazardous of  EES  must wear approved fluct and place ir . Sweep up mat ainer or plastic I way from spill. connel out of area	rotective eyeweanto a container foterial using non-sliner within anotl Stay upwind and a. Stop spill or rote.	ar. Use a non- or later disposal. sparking material her container. I away from spill delease if it can be			
.3	Firefighting Procedures:	uninvolved co bursting. If ac and release flac containers co. Water Fog, Fo As in any fire, demand_ and water spray to runoff from fi natural water pressure self- or decomposi Before cleanin Equipment (P Small spills W combustible r not use water (e.g., plastic b Large spills: K release. Isola	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is completed ammable liquids and/or exposed gases if exposed to the policy spraying them with water until the fire has been exam, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well after cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including Not contained breathing apparatus to protect against poter tion products and oxygen deficiencies.  6. ACCIDENTIAL RELEASE MEASUR and any spill or leak, individuals involved in spill cleanup of the products are appropriate personal protective equipment including naterial such as vermiculite or sand to soak up the product or a material such as "speedy dry" to soak up material rooms, shovels, dustpans) and place into a plastic contained incompatible materials (e.g., organics such as oil) at the immediate hazard area and keep unauthorized personal protective equipment including the immediate hazard area and keep unauthorized personal terminaterials (e.g., organics such as oil) at the immediate hazard area and keep unauthorized personal protective equipment including the immediate hazard area and keep unauthorized personal terminaterials (e.g., organics such as oil) at the immediate hazard area and keep unauthorized personal protective equipment including the immediate hazard area and keep unauthorized personal protective equipment including the immediate hazard area and keep unauthorized personal protective equipment including the immediate hazard area and keep unauthorized personal protective equipment including the immediate hazard area and keep unauthorized personal protective equipment including the immediate hazard area and keep unauthorized personal protective equipment including the immediate hazard area and keep unauthorized personal protective equipment including the immediate hazard ar	e projectile haza e. Containers me e heat of fire. K extinguished.  apparatus (prester the fire is our Fight fire upwind king water supploSH-approved atial hazardous of  EES  must wear approved fluct and place ir . Sweep up mat ainer or plastic I way from spill. connel out of area	rotective eyeweanto a container foterial using non-sliner within anotl Stay upwind and a. Stop spill or rote.	ar. Use a non- or later disposal. sparking material her container. I away from spill delease if it can be			
.3	Firefighting Procedures:	uninvolved co bursting. If ac and release flac containers co. Water Fog, Fo As in any fire, demand_ and water spray to runoff from fi natural water pressure self- or decomposi Before cleanin Equipment (P Small spills W combustible r not use water (e.g., plastic b Large spills: K release. Isola done with min	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is completed ammable liquids and/or exposed gases if exposed to the policy spraying them with water until the fire has been exam, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well after cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including Not contained breathing apparatus to protect against poter tion products and oxygen deficiencies.  6. ACCIDENTIAL RELEASE MEASUR agany spill or leak, individuals involved in spill cleanup apperatus to a separatus to soak up the process or a material such as vermiculite or sand to soak up the process or a material such as "speedy dry" to soak up material rooms, shovels, dustpans) and place into a plastic contained incompatible materials (e.g., organics such as oil) at the immediate hazard area and keep unauthorized personimal risk. Wear appropriate protective equipment including himself in the immediate hazard area and keep unauthorized personimal risk. Wear appropriate protective equipment including himself includi	e projectile haza e. Containers me e heat of fire. K extinguished.  apparatus (prester the fire is our Fight fire upwind king water supploSH-approved atial hazardous of the supploSH approved atial hazardous of the supplose and proved	rotective eyeweanto a container foterial using non-sliner within anotl Stay upwind and a. Stop spill or rote.	ar. Use a non- or later disposal. sparking material her container. I away from spill delease if it can be			
5.3	Firefighting Procedures:	uninvolved cobursting. If ac and release flacontainers cool Water Fog, For As in any fire, demand_and water spray to runoff from finatural water pressure selfor decomposis.  Before cleaning Equipment (Pamall spills Water Spills Water Spills Water (e.g., plastic barge spills: Karelease. Isola done with minimal spills with minimal spills water (e.g., plastic barge spills: Karelease. Isola done with minimal spills water (e.g., plastic barge spills: Karelease. Isola done with minimal spills water (e.g., plastic barge spills: Karelease. Isola done with minimal spills water (e.g., plastic barge spills: Karelease. Isola done with minimal spills water (e.g., plastic barges spills: Karelease. Isola done with minimal spills water (e.g., plastic barges spills: Karelease. Isola done with minimal spills water (e.g., plastic barges spills: Karelease. Isola done with minimal spills water (e.g., plastic barges spills: Karelease. Isola done with minimal spills water (e.g., plastic barges spills: Karelease. Isola done with minimal spills water (e.g., plastic barges spills: Karelease. Isola done with minimal spills water (e.g., plastic barges spills: Karelease. Isola done with minimal spills water (e.g., plastic barges spills: Karelease. Isola done with minimal spills water (e.g., plastic barges spills: Karelease. Isola done with minimal spills water (e.g., plastic barges spills: Karelease. Isola done with minimal spills water (e.g., plastic barges spills: karelease. Isola done with minimal spills water (e.g., plastic barges spills: karelease. Isola done with minimal spills water (e.g., plastic barges spills: karelease. Isola done with minimal spills water (e.g., plastic barges spills: karelease. Isola done water (e.g., plastic barges spills: ka	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is completed ammable liquids and/or exposed gases if exposed to the old by spraying them with water until the fire has been earn, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well afto cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including Not contained breathing apparatus to protect against poter tion products and oxygen deficiencies.  6. ACCIDENTIAL RELEASE MEASUR agany spill or leak, individuals involved in spill cleanup to the product of the protection and the product of th	e projectile haza e. Containers me e heat of fire. K extinguished.  apparatus (prester the fire is our Fight fire upwinking water supploSH-approved ntial hazardous of  EES  must wear approved fuct and place ir Sweep up mate ainer or plastic I way from spill.  connel out of area luding respirator  ATION	rotective eyeweanto a container fiterial using non-stay upwind and a. Stop spill or rory protection as	ar. Use a non- or later disposal. sparking material her container. I away from spill o elease if it can be conditions warra			
5.1	Firefighting Procedures:  Spills:	uninvolved cobursting. If ac and release flacontainers coo Water Fog, Fo As in any fire, demand_ and water spray to runoff from finatural water pressure selfor decomposi  Before cleaning Equipment (P. Small spills W. combustible runot use water (e.g., plastic b. Large spills: K. release. Isola done with minum To not use tat, dr. Do not eat, dr.	ntainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is completed ammable liquids and/or exposed gases if exposed to the old by spraying them with water until the fire has been earn, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well afto cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including Not contained breathing apparatus to protect against poter tion products and oxygen deficiencies.  6. ACCIDENTIAL RELEASE MEASUR agany spill or leak, individuals involved in spill cleanup to the process of the pr	e projectile haza e. Containers me e heat of fire. K extinguished.  apparatus (prester the fire is our Fight fire upwinking water supploSH-approved ntial hazardous of  EES  must wear approved auticular and place ir Sweep up material way from spill. Some out of area luding respirator  ATION  der pressure. F	rotective eyeweanto a container feterial using non-sliner within anotic Stay upwind and a. Stop spill or recry protection as	ar. Use a non- or later disposal. sparking material her container. I away from spill o elease if it can be conditions warra			
	Firefighting Procedures:	uninvolved cobursting. If ac and release flacontainers coo Water Fog, Fo As in any fire, demand_and water spray to runoff from fi natural water pressure selfor decomposi  Before cleanir Equipment (P Small spills W combustible runot use water (e.g., plastic b Large spills: K release. Isola done with min Do not eat, dr container(s).	Intainers to prevent possible bursting. Aerosols may be prosols are bursting, stay clear until bursting is completed ammable liquids and/or exposed gases if exposed to the play spraying them with water until the fire has been exam, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well afto cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including Not contained breathing apparatus to protect against poter betton products and oxygen deficiencies.  6. ACCIDENTIAL RELEASE MEASUR and spill or leak, individuals involved in spill cleanup of the protection and the protection and the protection are material such as "speedy dry" to soak up the protection or a material such as "speedy dry" to soak up material rooms, shovels, dustpans) and place into a plastic contained incompatible materials (e.g., organics such as oil) at the immediate hazard area and keep unauthorized personal risk. Wear appropriate protective equipment including this product. Contents unwhen used as intended, no additional protective equipwell.	e projectile haza e. Containers me e heat of fire. K extinguished.  apparatus (prester the fire is our Fight fire upwinking water supploSH-approved ntial hazardous of  EES  must wear approved auticular and place in Sweep up matainer or plastic l way from spill. connel out of area luding respirator  ATION  der pressure. Filment is necessa	rotective eyeweanto a container feterial using non-sliner within anotic Stay upwind and a. Stop spill or recry protection as	ar. Use a non- or later disposal. sparking material her container. I away from spill o elease if it can be conditions warra			
5.1	Firefighting Procedures:  Spills:	uninvolved cobursting. If ac and release flacontainers coo Water Fog, Fo As in any fire, demand_and water spray to runoff from fi natural water pressure selfor decomposi  Before cleanir Equipment (P Small spills W combustible runot use water (e.g., plastic b Large spills: K release. Isola done with min Do not eat, drontainer(s). contact is pos	Intainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is completed ammable liquids and/or exposed gases if exposed to the old by spraying them with water until the fire has been earn, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well afto cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including Not contained breathing apparatus to protect against poter tion products and oxygen deficiencies.  6. ACCIDENTIAL RELEASE MEASUR and spill or leak, individuals involved in spill cleanup of the protection and the protection and the protection are material such as "speedy dry" to soak up the protection or a material such as "speedy dry" to soak up material rooms, shovels, dustpans) and place into a plastic contained incompatible materials (e.g., organics such as oil) at the immediate hazard area and keep unauthorized personal risk. Wear appropriate protective equipment including this product. Contents unwhen used as intended, no additional protective equipment when used as intended, no additional protective equipment including the used as intended, no additional protective equipment including the used as intended, no additional protective equipment including the used as intended, no additional protective equipment including the used as intended, no additional protective equipment including the used as intended, no additional protective equipment including the used as intended, no additional protective equipment including the used as intended, no additional protective equipment including the used as intended, no additional protective equipment including the used as intended, no additional protective equipment including the used as intended, no additional protective equipment including the used as intended and used the used to the unit to the used to the used to the unit to the used to the unit	e projectile haza e. Containers m e heat of fire. K extinguished.  apparatus (prester the fire is our Fight fire upwinking water supploSH-approved ntial hazardous of  EES  must wear approved project and place in Sweep up matainer or plastic livery from spill.  connel out of area luding respirator  ATION  der pressure. Firement is necessary water.	rotective eyeweanto a container feterial using non-sliner within anot! Stay upwind and a. Stop spill or re ry protection as	ar. Use a non- or later disposal. sparking material her container. d away from spill of elease if it can be conditions warran d puncturing al goggles if eye			
5.1	Firefighting Procedures:  Spills:	uninvolved cobursting. If ac and release flacontainers coo Water Fog, Fo As in any fire, demand_and water spray to runoff from fi natural water pressure selfor decomposi  Before cleanir Equipment (P Small spills W combustible runot use water (e.g., plastic b Large spills: K release. Isola done with min Do not eat, drontainer(s). contact is pos	Intainers to prevent possible bursting. Aerosols may be prosols are bursting, stay clear until bursting is completed ammable liquids and/or exposed gases if exposed to the play spraying them with water until the fire has been exam, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well afto cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including Not contained breathing apparatus to protect against poter betton products and oxygen deficiencies.  6. ACCIDENTIAL RELEASE MEASUR and spill or leak, individuals involved in spill cleanup of the protection and the protection and the protection are material such as "speedy dry" to soak up the protection or a material such as "speedy dry" to soak up material rooms, shovels, dustpans) and place into a plastic contained incompatible materials (e.g., organics such as oil) at the immediate hazard area and keep unauthorized personal risk. Wear appropriate protective equipment including this product. Contents unwhen used as intended, no additional protective equipwell.	e projectile haza e. Containers m e heat of fire. K extinguished.  apparatus (prester the fire is our Fight fire upwinking water supploSH-approved ntial hazardous of  EES  must wear approved project and place in Sweep up matainer or plastic livery from spill.  connel out of area luding respirator  ATION  der pressure. Firement is necessary water.	rotective eyeweanto a container feterial using non-sliner within anot! Stay upwind and a. Stop spill or re ry protection as	ar. Use a non- or later disposal. sparking material her container. d away from spill of elease if it can be conditions warran d puncturing al goggles if eye			
5.1	Firefighting Procedures:  Spills:	uninvolved cobursting. If ac and release flacontainers coo Water Fog, Fo As in any fire, demand_ and water spray to runoff from fi natural water pressure self-or decomposi  Before cleanir Equipment (P Small spills W combustible runot use water (e.g., plastic b Large spills: K release. Isola done with min Do not eat, dr container(s). contact is positive and store water (e.g. and store water (e.	Intainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is completed ammable liquids and/or exposed gases if exposed to the old by spraying them with water until the fire has been earn, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well afto cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including Not contained breathing apparatus to protect against poter tion products and oxygen deficiencies.  6. ACCIDENTIAL RELEASE MEASUR and spill or leak, individuals involved in spill cleanup of the protection and the protection and the protection are material such as "speedy dry" to soak up the protection or a material such as "speedy dry" to soak up material rooms, shovels, dustpans) and place into a plastic contained incompatible materials (e.g., organics such as oil) at the immediate hazard area and keep unauthorized personal risk. Wear appropriate protective equipment including this product. Contents unwhen used as intended, no additional protective equipment when used as intended, no additional protective equipment including the used as intended, no additional protective equipment including the used as intended, no additional protective equipment including the used as intended, no additional protective equipment including the used as intended, no additional protective equipment including the used as intended, no additional protective equipment including the used as intended, no additional protective equipment including the used as intended, no additional protective equipment including the used as intended, no additional protective equipment including the used as intended, no additional protective equipment including the used as intended, no additional protective equipment including the used as intended and used the used to the unit to the used to the used to the unit to the used to the unit	e projectile haza e. Containers m e heat of fire. K extinguished.  apparatus (prester the fire is our Fight fire upwinking water supplication of the containers of the containers of the containers of the container or plastic laway from spill.  ATION Inder pressure. Figure 1 is necessary water.  ust ventilation, f	rotective eyeweanto a container feterial using non-sliner within anot! Stay upwind anca. Stop spill or rery protection as	ar. Use a non- or later disposal. sparking material her container. d away from spill delease if it can be conditions warran d puncturing al goggles if eye heat and direct			
5.1	Spills:  Work & Hygiene Practices	uninvolved cobursting. If ac and release flacontainers coo Water Fog, Fo As in any fire, demand_ and water spray to runoff from fi natural water pressure selfor decomposi  Before cleaning Equipment (P. Small spills W. combustible runot use water (e.g., plastic b. Large spills: Korelease. Isola done with minum to the container (s). Contact is positive unlight. Avoid water for the container (s). Contact is positive sunlight. Avoid water for the container (s).	Intainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is complete ammable liquids and/or exposed gases if exposed to the blood by spraying them with water until the fire has been eam, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well afto cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including Not contained breathing apparatus to protect against poter betton products and oxygen deficiencies.  6. ACCIDENTIAL RELEASE MEASUR and spill or leak, individuals involved in spill cleanup of the protection and place into a plastic contained in the protection and	e projectile haza e. Containers m e heat of fire. K extinguished.  apparatus (prester the fire is our Fight fire upwinking water supplications)  EES  must wear approved a product and place in Sweep up mater and place in Sweep up mater or plastic laway from spill.  Ponnel out of area luding respirator  ATION Inder pressure. Homent is necessary water.  Just ventilation, fincompatible su	rotective eyeweanto a container foterial using non-sliner within anot! Stay upwind and a. Stop spill or rorry protection as	ar. Use a non- or later disposal. sparking material her container. I away from spill o elease if it can be conditions warral d puncturing al goggles if eye heat and direct ct containers fror			
5.3	Spills:  Work & Hygiene Practices	uninvolved cobursting. If ac and release flacontainers coo Water Fog, Fo As in any fire, demand_and water spray to runoff from fi natural water pressure selfor decomposion before cleaning Equipment (P. Small spills W. combustible runot use water (e.g., plastic b. Large spills: Krelease. Isola done with min Do not eat, dr. container(s). contact is post Use and store sunlight. Avo physical dame	Intainers to prevent possible bursting. Aerosols may be crosols are bursting, stay clear until bursting is complete ammable liquids and/or exposed gases if exposed to the blood by spraying them with water until the fire has been eam, CO <sub>2</sub> , Dry Chemical wear MSHA/NIOSH approved self-contained breathing full protective gear. Keep containers cool until well afto cool fire-exposed surfaces and to protect personnel. The control or dilution from entering sewers, drains, dring way. Firefighters must use full bunker gear including Not contained breathing apparatus to protect against poter betton products and oxygen deficiencies.  6. ACCIDENTIAL RELEASE MEASUR and spill or leak, individuals involved in spill cleanup and the protection and the protectio	e projectile haza e. Containers m e heat of fire. K extinguished.  apparatus (prester the fire is our Fight fire upwinding water supplications)  EES  must wear approved a product and place ir . Sweep up matainer or plastic I way from spill.  apparatus (prester the fire is our Euch fire upwinding water supplications)  ATION Inder pressure. He ment is necessary in water.  ust ventilation, fincompatible su when not in use	rotective eyeweanto a container feterial using non-sliner within anot! Stay upwind and a. Stop spill or rorry protection as	ar. Use a non- or later disposal. sparking material her container. I away from spill o elease if it can be conditions warral d puncturing al goggles if eye heat and direct ct containers fror			



KIK - B-9833D

Prepared to OSHA, ACC, ANSI, NOHSC, WHMIS, 2001/58 & 1272/2008/EC Standards SDS Revision: 1.0 SDS Revision Date: 11-16-2016 8. EXPOSURE CONTROLS & PERSONAL PROTECTION **Exposure Limits:** ACGIH NOHSC OSHA OTHER ES-STEL STEL Ppm (mg/m<sup>3</sup>) Chemical Name(s) TLV STEL **ES-TWA ES-PEAK** PEL **IDLH** Ethanol (SD Alcohol 40B) 1000 3000 1000 1800 NF 1000 1900 3300 **DIFLUOROETHANE (R-152a)** 1000 NA 1000 NA NA NA NA NE 8.2 Ventilation & Engineering General mechanical (e.g., fans) or natural ventilation is sufficient when this product is in use. Use local or general exhaust ventilation to effectively remove and prevent buildup of vapors or mist generated from the handling of this Controls product. 8.3 **Respiratory Protection:** No special respiratory protection is required under typical circumstances of use or handling. In instances where dusts of this product are generated, and respiratory protection is needed, use only protection authorized by 29 CFR §1910.134, applicable U.S. State regulations, or the Canadian CAS Standard Z94.4-93 and applicable standards of Canadian Provinces, EC member States, or Australia. 8.4 Eye Protection: None required under normal conditions of use. Avoid eye contact. Safety glasses should be used when handling or using large quantities of this product (e.g., > 1 gallon (3.8 L)). None required under normal conditions of use. However, may cause skin irritation is some 8.5 Hand Protection: sensitive individuals. When handling large quantities (e.g.,  $\geq$  1 gallon (3.8 L)), wear rubber, nitrile or impervious plastic gloves. No apron required when handling small quantities. When handling large quantities (e.g., ≥ 8.6 **Body Protection:** 5 lbs.), eye wash station and deluge showers should be available. Upon completion of work activities involving large quantities of this product, wash any exposed areas thoroughly with soap and water. 9. PHYSICAL & CHEMICAL PROPERTIES Appearance: 9.1 Aerosol, misty spray Fresh Sweet odor 9.2 Odor: Odor Threshold 9.3 NA NA Melting/Freezing Point 9.5 NA 9.6 Initial Boiling Point/ Boiling NA Range: Flashpoint: -30 °F (-34 °C) TCC for propellant only; 35.6 °F (2 °C) EPA method 1010 Concentrate only 9.7 Upper/Lower Flammability NA 9.8 limits 9.9 Vapor Pressure: @ 20 °C (68° F) - Can pressure not to exceed 180 psig @ 55 °C (131 °F) 12.4 bar 9.10 Vapor Density >1 Relative Density: 0.84 - 0.949.11 Solubility: Soluble **Partition Coefficient** 9.13 NA ( $\log P_{ow}$ ): Autoignition Temperature: NA 9.15 Decomposition NA Temperature. Viscosity: Aerosol at ambient temperature 9.17 Other Information: Evaporation Rate >1: Percent Volatile 55% 10. STABILITY & REACTIVITY Stable at normal temperatures. 10.1 Stability: Hazardous Decomposition 10.2 Oxides of carbon (CO, CO<sub>2</sub>) and sulfur (SO<sub>2</sub>) Products: Hazardous Polymerization: 10.3 Will not occur. Excessive heat, direct sunlight, flames, heat sources and incompatible substances. Conditions to Avoid 10.5 Incompatible Substances Mixture with strong acids, alkalis or oxidizers.



KIK - B-9833D

Prepared to OSHA, ACC, ANSI, NOHSC, WHMIS, 2001/58 & 1272/2008/EC Standards SDS Revision: 1.0 SDS Revision Date: 11-16-2016								
11. TOXICOLOGICAL INFORMATION								
	Routes of Entry:	Inhalation: YES Absorption: YES Ingestion: YES						
	Toxicity Data:	This product was not tested on animals.						
	Acute Toxicity:	See Section 4.4						
	Chronic Toxicity:	See Section 4.5						
	Suspected Carcinogen:	NA						
11.6	Reproductive Toxicity:	This product is not reported to cause reproductive toxicity in humans.						
	Mutagenicity: This product is not reported to produce mutagenic effects in humans.							
	Embryotoxicity: This product is not reported to produce embryotoxic effects in humans.							
	Teratogenicity:	This product is not report to cause teratogenic effects in humans.						
	Reproductive Toxicity:	This product is not report to cause reproductive effects in humans.						
	Irritancy of Product:							
11.8	Biological Exposure	NA NA						
44.0	Indices:							
11.9	Physician Recommendations:	Treat symptomatically.						
	necommendations.	12. ECOLOGICAL INFORMATION						
12.1	Environmental Stability:	There is no specific data available for this product.						
		There is no specific data available for this product.						
	Effects on Aquatic Life:	The product itself has not been tested as a whole. There is no specific data available for this product.						
12.3	Lifects off Aquatic Life.	The product itself has not been tested as a whole. There is no specific data available for this product.						
		13. DISPOSAL CONSIDERATIONS						
42.4	W . B: 1							
13.1	Waste Disposal:	Review current local, state and federal laws, codes, statutes and regulations to determine current status and						
		appropriate disposal method for the ingredients listed in Section 2. Any disposal practice must be in compliance with						
		local, state and federal laws and regulations. Contact the appropriate agency for specific information. A licensed facility or waste hauler must provide treatment, transport, storage and disposal of hazardous waste.						
12.2	Special Considerations:	U.S. EPA Hazardous Waste – Characteristic – Ignitable (D001)						
13.2	Special Considerations.	U.S. LFA Hazardous Waste - Characteristic - Ignitable (D001)						
		14. TRANSPORTATION INFORMATION						
14.1	49 CFR (GND):	UN1950, AEROSOLS, 2.1 (LTD QTY, IP VOL <u>&lt;</u> 1.0 L); or						
		CONSUMER COMMODITY, ORM-D (IP VOL ≤ 1.0 L) – until 12/31/2020						
14.2	IATA (AIR)	UN1950, AEROSOLS, FLAMMABLE, 2.1 (LTD QTY, IP VOL $\leq$ 0.5 L); or						
		ID8000, CONSUMER COMMODITY, ORM-D (IP VOL < 0.5 I=L)						
14.3	IMDG (OCN):	UN1950, AEROSOLS, 2.1 (LTD QTY, IP VOL <u>&lt;</u> 1.0 L)						
14.4	TDGR (Canadian GND):	UN1950, AEROSOLS, 2.1 (LTD QTY, IP VOL < 1.0 L); or						
		MARK PACKAGE "LIMITED QUANTITY", "LTD QTY", OR "QUANT LTÉE" OR "QUANTITÉ LIMITÉE"						
	ADR/RID (EU):	UN1950, AEROSOLS, 2.1 (LTD QTY, IP VOL < 1.0 L)						
14.6	SCT (MEXICO):	UN1950, AEROSOLES, 2.1 (CANTIDAD LIMITADA, IP VOL < 1.0 L)						
14.7	ADGR (AUS):							
		UN1950, AEROSOLS, 2.1 (LTD QTY, IP VOL $\leq$ 1.0 L)						
		1011330, AEROSOES, 2.1 (EID Q11, II VOE < 1.0 L)						
15. REGULATORY INFORMATION								
15.1	SARA Reporting Requirements:	This product does not contain any substance subject to SATA Title III, section 313 reporting requirements.						
15 2	SARA Threshold Planning							
13.2	Quantity:	There are no specific Threshold Planning Quantities for the components of this product.						
	TSCA Inventory Status:	The components of this product are listed on the TSCA Inventory.						
	CERCLA Reportable							
	Quantity (RQ):	Ethanol: 2270 kg; 5000 lbs						
15.5	Other Federal	This product complies with the appropriate sections of the Food and Drug Administration's 21 CFR Subchapter G.						
	Requirements:	(Cosmetics)						



KIK - B-9833D

_		ISI, NOHSC, WHMIS, 2001/58 & 1272/2008/EC Standards	SDS Revision: 1.0 SDS Revision Date: 11-16-2016					
15.6	Other Canadian	This product has been classified according to the hazard criteria of the CPR and the SDS contains all of the information required by the CPR. The components of the product are listed on the DSL/NDSL. None of						
	Regulations:							
		the components of this product are listed on the Prioritie	es Substance List. WHMIS Class B5 (Flammable					
		Aerosol)						
15.7	,	Ethanol: is found on the following state criteria lists FL, N						
	Information:	Butane can be found on the following state criteria lists:						
		Difluoroethane can be found on the following state criter						
			tration of 1.0% or greater, are listed on any of the following					
		state criteria lists: California Proposition 65 (CA65), Delaware Air Quality Management List (DE), Florida Toxic Sul						
	List (FL), Massachusetts Hazardous Substances List (MA), Michigan Critical Substances List (MI), New Jersey Right-to-Know List (NJ), New York Hazardous Substances List (NY)							
			•					
45.0	Other Demiliance atom	to-Know List (PA), Washington Permissible Exposures List	t (WA), Wisconsin Hazardous Substances List (WI).					
15.8	Other Requirements:							
		The primary components of this product are listed in Anr	nex Lof FIL Directive 67/548/FFC					
		<u>Butane:</u> Flammable (F+). <u>Risk Phrases</u> (R): 12 – Extreme						
		Keep out of reach of children. Keep in cool storage area						
		ventilated place. Keep away from sources of ignition – N	· · · · · · · · · · · · · · · · · · ·					
		instructions before use. In case of accident, or if you feel						
		Ethanol : Flammable (F). Risk Phrases (R): 11 – Flammabl						
		children. Keep container tightly closed. Keep away from						
		16. OTHER INFORMA	TION					
16.1	Other Information:		TAINER: MAY BURST IF HEATED, HIGHLY FLAMMABLE LIQUID					
		AND VAPORS. CAUSES EYE IRRITATION. Keep away from	m heat, hot surfaces, sparks open flames and other ignition					
			other ignition source. Do not pierce or burn, even after use.					
Avoid breathing vapor/spray. Wash thoroughly with soap and water after handling. Use only in a well ven								
		Wear eye protection. Protect from sunlight. Do not exp						
			eathing. IF IN EYES: Rinse cautiously with water for several					
minutes. Remove contact lenses if present and easy to do. Continue rinsing. If eye irritation persists: Get m								
advice/attention. KEEP PRODUCT LOCKED-UP AND OUT OF REACH OF CHILDREN.								
16.2		See last page of this Safety Data Sheet.						
16.3	Disclaimer:	This Safety Data Sheet is offered pursuant to OSHA's Hazard Communication Standard, 29 CFR §1910.1200. Other						
		ty to this product. To the base of KIK Custom Product's						
		knowledge, the information contained herein is reliable and accurate as of this date; however, accuracy, suitability or						
complete=ness are not guaranteed and no warranties of any type, either expressed or implied, are processed and accomplete and								
information contained herein relates only to the specific product(s). If this product(s) is combined wi								
			be changed from time to time. Be sure to consult the latest					
		edition.						
16.4	Prepared By:	KIK Custom Products	//// VIV					
		2730 Middlebury Street	KIK CUSTOM PRODUCTS					
		Elkhart, Indiana USA	CUSTOM PRODUCTS					
		http://www.kikcorp.com						



KIK - B-9833D

Prepared to OSHA, ACC, ANSI, NOHSC, WHMIS, 2001/58 & 1272/2008/EC Standards SDS Revision: 1.0 SDS Revision Date: 11-16-2016 **Explosive** Oxidizer Flammable Corrosive Toxic Pressurized Harmful/Irritating Health Hazard Environment Face Shield and Protective **Dust Mask** Apron Eyewear **Full Suit Protective Clothing** Safety Glasses Boots Gloves



KIK - B-9833D

Prepared to OSHA, ACC, ANSI, NOHSC, WHMIS, 2001/58 & 1272/2008/EC Standards

SDS Revision: 1.0 SDS Revision Date: 11-16-2016

Full Face Respirator

Reactive

Irritant / Harmful

Biohazard

Oxidizing

Flammable

Compressed

Toxic

Irritation